



NOTES:

1. RIGHT-OF-WAY WIDTHS, EASEMENTS, AND PAVEMENT SECTIONS SHOWN ARE MINIMUM REQUIREMENTS.
2. PAVED WIDTH IS MEASURED FROM CURB FLOW LINE TO CURB FLOW LINE.
3. ALL SIDEWALKS SHALL BE LOCATED AS SHOWN ON THE APPROVED PLANS.
4. WHERE CONTINUOUS SWALE IS NOT PROVIDED, THE SEPARATION BETWEEN BACK OF CURB TO FACE OF SIDEWALK MAY BE REDUCED TO A 6' PLANTER STRIP.
5. MAXIMUM ALLOWABLE SLOPES WITHIN RIGHTS-OF-WAY OR EASEMENTS SHALL BE 3H:1V. WHERE BICYCLE OR PEDESTRIAN FACILITIES EXIST NEAR THE EDGE OF EASEMENTS, THE 3H:1V SLOPE SHALL EXTEND AT LEAST 5' BEYOND SAID FACILITY.

APPROVED BY:

 CITY ENGINEER, P.E. 3/19/19 DATE:

POST FALLS STANDARDS FOR PUBLIC WORKS CONSTRUCTION
**TYPICAL STREET SECTION,
 LOCAL COMMERCIAL / INDUSTRIAL**

STANDARD DRAWING
 NO. SD 2002