



NOTE:

1. MANHOLE DIAMETERS SHALL BE 48" FOR PIPE DIAMETERS 24 INCHES OR LESS, UNLESS INDICATED OTHERWISE ON THE PLANS.
2. EXTERIOR DROPS SHALL USE RESTRATINED FITTINGS THAT ARE COATED PER ISPWC SECTION 500 2.2
3. EXTERIOR DROPS SHALL BE BACKFILLED WITH A CONTROLLED DENSITY FILL (CDF) EXTENDING A MINIMUM OF 6-INCHES FROM ALL SIDES.

APPROVED BY:

POST FALLS STANDARDS FOR PUBLIC WORKS CONSTRUCTION

[Signature] 3/19/19
 CITY ENGINEER, P.E. DATE:

DROP MANHOLE DETAIL

STANDARD DRAWING
 NO. SD 502