

2"X4" MARKER; EXPOSED A MINIMUM OF 12" AND PAINTED GREEN

12 GAUGE GALVANIZED WIRE (FASTEN TO BOTTOM OF STAKE)

LOCATING BALL; MAXIMUM 4 FEET BELOW SURFACE

CAP OR PLUG UNLESS JOINING EXIST. SERVICE

5' MIN. BEHIND PROPERTY LINE  
PL

5' MIN.

MIN. GRADE 1/4"/FT  
1/8"/FT IF APPROVED

TYPE "A"

BEND AS REQUIRED, TAP INTO TOP HALF OF SEWER LATERAL

2"X4" MARKER; EXPOSED A MINIMUM OF 12" AND PAINTED GREEN

12 GAUGE GALVANIZED WIRE (FASTEN TO BOTTOM OF STAKE)

LOCATING BALL; MAXIMUM 4 FEET BELOW SURFACE

CAP OR PLUG UNLESS JOINING EXIST. SERVICE

5' MIN. BEHIND PROPERTY LINE  
PL

5' MIN.

MIN. GRADE 1/4"/FT  
1/8"/FT IF APPROVED

TYPE "B"

4"-1/8 OR 1/16 BEND AS NEEDED

RUBBER RING TYPE ADAPTER OR CONNECTION PER MANUFACTURERS RECOMMENDATION

SEWER MAIN

**NOTES:**

1. 4" PIPE UNLESS OTHERWISE SPECIFIED.
2. 4" TEE ROTATE 45° FROM HORIZONTAL UNLESS OTHERWISE SPECIFIED.
3. DEPTH AT PROERTY LINE SHALL BE AS AS INDICATED ON THE PLANS, 5 FT MINIMUM.

APPROVED BY:

POST FALLS STANDARDS FOR PUBLIC WORKS CONSTRUCTION

*[Signature]* 3/19/19  
CITY ENGINEER, P.E. DATE:

**SEWER SERVICE LINE  
TYPES A & B**

STANDARD DRAWING  
NO. SD 503