



NOTES:

1. UNDERDRAIN TO BE "WILBERT PRECAST" SPECIAL CURB INLET TYPE 2 (MODEL 1840) OR APPROVED EQUAL.
2. SIDEWALK PROFILE GRADES SHALL BE ADJUSTED TO ACCOMODATE THE UNDERDRAIN ELEVATION. MAXIMUM PROFILE GRADE 5%.

APPROVED BY:

POST FALLS STANDARDS FOR PUBLIC WORKS CONSTRUCTION

[Signature] 3/19/19
CITY ENGINEER, P.E. DATE:

**SIDEWALK UNDERDRAIN
(CURB SEPARATED)**

STANDARD DRAWING
NO. SD 605