

CITY OF POST FALLS STANDARD FOR A. V. B. INSTALLATION RE.: LANDSCAPE IRRIGATION SYSTEM

ATMOSPHERIC VACUUM BREAKER BACKSIPHONAGE PREVENTION ASSEMBLY (AVB)
IS AN "UNTESTABLE" APPROVED BACKFLOW PREVENTION ASSEMBLY.

NOTE: ASSEMBLY SHALL NOT BE SUBJECTED TO OPERATING PRESSURE
FOR MORE THAN TWELVE (12) HOURS IN ANY TWENTYFOUR (24) HOUR PERIOD.

